



Certificate Examination of Conformity

Certificate No.:	KP117
Certification Body:	TÜV SÜD Industrie Service GmbH Westendstr. 199, 80686 München - Germany
Applicant/ Certificate Holder:	EITA-SCHNEIDER (MFG) SDN.BHD. Lot 4, Block A, Jalan SS 13/7, Subang Jaya Industrial Estate, 47500 Subang Jaya, Selangor Darul Ehsan - Malaysia
Date of application:	2011-01-12
Manufacturer:	EITA-SCHNEIDER (MFG) SDN.BHD. Lot 4, Block A, Jalan SS 13/7, Subang Jaya Industrial Estate, 47500 Subang Jaya, Selangor Darul Ehsan - Malaysia
Product, Type:	Escalator, ESIEsc
Scope of application:	Rise 2,0 m to 16,0 m, depending on: - step width (600 / 800 / 1000) - inclination (27,3° / 30° / 35°) - rated speed: 0,5 m/s
Test laboratory:	TÜV SÜD Industrie Service GmbH Prüflaboratorium für Produkte der Fördertechnik Prüfbereich Aufzüge und Sicherheitsbauteile Westendstraße 199, 80686 München - Germany
Date and Number of Test Report:	2011-08-10 KP 117
Test specifications:	- 2006/42/EC, Annex I - EN115-1:2008+A1:2010
Validity:	This certificate is valid until 2016-08-10
Result:	The escalator ESIEsc fulfils the requirements of the test specifications for the respective scope of application stated in the annex, page 1, of this certificate, keeping the mentioned conditions.
Date of issue:	2011-08-10

Certification body for lifts and cranes


 Christian Rührmeyer

